

AC 10/2020

ORAS
BERBESTI



spre Mateesti
LEA 0,4 KV alimentata
din PTA Berbesti #2

Bloc de masura si protectie
trifazat BMPT 32A proiectat

cablu ACYY 4x25mm
proiectat-Lmax=16m

SE4 ex.

str. Principala

JUDETUL VALCEA
PRIMARIA COMUNEI
BERBESTI

VIZAT SI DE NESCHIMBARE

Anexa la autorizatia de construire
desfiintare

Nr. 10 din 04.09.2020

TEHNICIAN URBANISM SI AMENAJAREA
TERITORIILOR



LEGENDA

- LEA JT existenta
- Bransament electric trifazat subteran proiectat in lungime de 16m (traseu 4m pamant)
- Stalp J.T. existent
- Bloc de masura si protectie proiectat

VERIFICATOR/ EXPERT	NUME	SEMNAURA	CERINTA	REFERAT/EXPERTIZA NR./DATA	PROIECT NR.
S.C. TEMPOS SERV S.R.L. <small>servicii complete in electricitate</small>				BENEFICIAR: SC DISTRIBUTIE ENERGIE OLTENIA SA - VALCEA	
SPECIFICATIE	NUME	SEMN.	Scara 1/1000	Denumire proiect: BRANSAMENT ELECTRIC TRIFAZAT SUBTERAN - ANEXA GOSPODAREASCA - [redacted] STR. PRINCIPALA, NR. 245, ORAS BERBESTI, JUD. VALCEA	FAZA A.C.
SEF PROIECT	ing. Biscu Ion		Data	Denumire plansa: PLAN DE SITUATIE PROIECTAT	Plansa nr. 2
PROIECTAT	ing. Biscu Ion		Aug. 2020		
DESENAT	ing. Biscu Ion				